



January 25, 2018

File: 21020-50/WW/OP/Ituna

Town of Ituna  
Box 580  
ITUNA, SK S0A 1N0

Attention: Mayor and Council:

**RE: Rescinding - Precautionary Drinking Water Advisory – Town of Ituna**

The Water Security Agency, in consultation with the Sunrise Health Region, are advising that the "Precautionary Drinking Water Advisory"(PDWA) issued by the Water Security Agency for the Town of Ituna's potable water system be rescinded as of 3:30 pm Thursday January 25, 2018.

The rescinding of the PDWA was based upon information provided by your community, which included:

- Water main repair has been completed;
- The pressure in the distribution system is back to normal operating pressure;
- The turbidity in the system is within regulatory requirements;
- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Town of Ituna in addressing the advisory.

Sincerely,

A handwritten signature in black ink, appearing to read "Derrick Hoehn".

Derrick Hoehn, A.Sc.T  
Sr. Environmental Project Officer  
Environmental & Municipal Management Services Division  
Water Security Agency

cc: Greg Holvach, South Manager, WSA  
Verna Law, Public Health Inspector, MOH  
Gilbert Combres, Senior Public Health Inspector, MOH