

# Drinking Water Quality and Compliance Town of Ituna 2018 Annual Notice to Consumers

## Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a Waterworks. The following is a summary of the Town of Ituna water quality and sample submission compliance record for the 2017 time period. This report was completed on June 22, 2018. Readers should refer to Water Security Agency's [Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502](#) for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

## Water Quality Standards

### Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL			
E. coli	0 Organisms/100 mL			
Background Bacteria	Less than 200/100 mL	52	56	0

### Water Disinfection – Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	.10 – 2.14	.09 – 1.64	52	56	98

### Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records- From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	.36 – 1.90	366	0

*A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.*

### Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1	.12 – .28	0	.28	365	366

## Health & Toxicity 2018

Parameter	Limit MAC(mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit
Aluminum			<6.96	
Arsenic	<10		<0.10	
Barium	<100		13.3	
Boron	<5.0		0.3	



Saskatchewan  
Ministry of  
Environment



Cadmium	<5	<0.15
Chromium	<50	0.20
Copper	<1000	208
Iron	0.1	<0.1
Lead	<10	0.30
Manganese	<0.05	<0.01
Selenium	<10	<1.13
Uranium	<20	<0.11
Zinc	<5000	9.2
Antimony		<0.16
Silver		<0.20

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on June 19, 2018. Sample results indicated that the provincial drinking water quality standards were not exceeded.

General Chemical 2017

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)	# Samples	
			Required	Submitted
Alkalinity	500	455	1	1
Bicarbonate	No Objective	555	1	1
Calcium	No Objective	143		
Carbonate	No Objective	0	1	1
Chloride	250 dissolved	25.5	1	1
Conductivity	No Objective	1762		
Hardness	800	724	1	1
Magnesium	200	<.01	1	1
PH	No Objective	7.6		
Sodium	300	152	1	1
Sulphate	500	556.2	1	1
Total dissolved Solids	1500	1535	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every 2 years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required by June 30, 2017 and submitted on May 9, 2017.

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

**More information on water quality and sample submission performance may be obtained from:**

Town of Ituna  
 7 – 1<sup>st</sup> Ave. N.E., PO Box 580, Ituna, Saskatchewan  
 Telephone: 306.795.2272 Fax: 306.795.3330  
 E-mail: [townofituna@sasktel.net](mailto:townofituna@sasktel.net)

